




ACE Test Software







AOV Software

Integrated

Design Calculation Software ACE




Test Analysis Software ACETEST




ACETest Software History

- 2008 ACETest Rev 0
 - Initial Release for Entergy Indian Point
- 2008 ACETest Rev 1
 - Minor rev
- 2009 ACETest Rev 2
 - Major changes for Entergy Corporate Use
- 2010 ACETest Rev 3
 - Renamed Software to ACETest
- 2012 ACETest Rev 4
 - Updated to Interface with ACE 4.0
- 2013 ACETest Rev 4.1
 - Total rewrite of software


- Add Valve (Manual)
 - Valve ID
 - **WO**
 - AOVDR Rev
 - Plant / Unit
 - Legacy Data




- Add WO
 - WO
 - AOVDR Rev
 - Legacy Data
 - Select WO to Copy
 - Legacy WO Excluded




- Pre-Test Inputs
 - Similar layout to ACE




- Design Inputs
 - Imported from ACE



- Design Inputs
 - Update Data Imported from ACE




- Pre-Test Inputs
 - Manual Valve
 - Includes Design & Pre-Test Inputs




Pre-Test Inputs

Valve Tab




Pre-Test Inputs


Actuator Tab




- Accessories
 - Imported from ACE
 - Additional Fields added




- Accessories
 - I/P Added




- Adjustment Factors
 - Not same as ACE




Test Requirements




- Seat Load Calc (QSS)
 - Device Dependant
 - Open Calc Optional
 - Detailed Calc in Report Optional




- Seat Load Calc (EDA)
 - Device Dependant
 - Open Calc Optional
 - Detailed Calc in Report Optional




AOV Setup Box




AOV Setup Box Targets




 AOV Setup Box Adjustments



AOV Setup Box
 Design Calculated Outputs



- Set Points
 - Used in Post Test Review



- Pre-Test Report
 - 2 to 5 pages long
 - Only variable applicable to valve type shown
 - Header fields customizable

Exelon Nuclear	Quality Related		
Limerick Unit 1	Informational Use	Sheet 1	of 4

			AC	OV Data Record For
AOVID:	FCV-006-112A	Work Order:	NEW W/O	
GENERAL DATA				
Valve Type:	Globe - Pilot - Flow Over		AOVDR Revision:	2
Actuator Type:	Diaphragm - Direct Acting			
Fail Position:	Open		AOVDR Status:	Pending / 1st Time
Calculation Reference:	TR-80088-1 Rev 0		IST:	No
Misc References:	DBR		LLRT:	No
Flow Diagram / P&ID:	94.16162-1		Thermal Perf:	No
0	Main Steam		Category:	1
System:	Main Steam		Primary AOV Function:	Control Valve
Description:	MSL Downstream drain line headrer bypass		SOV Limit IP EQ:	N/A

VALVE			
Valve Manufacturer:	BADGER METER CO	Valve Stem Diameter:	2,500 in.
Valve Model:	1002GCS36BVOPJLN36	Stem Material:	Stem Material 12345
Size:	0.50 in.	Young's Modulus (E):	29,000,000
Serial Number:	N/A	Poisson's Ratio (v):	0.301 psi
Valve PO Number:	V PO #	Rated Stroke Length / Tol:	3.625 in. / 1.00%

ACTUATOR			
Actuator Manufacturer:	BADGER METER CO	Actuator PO Number:	Act PO #
Actuator Model:	1002GCS36BVOPJLN36	Handwheel Mounting:	Тор
Actuator Size:	Act Size	Stoke Time Adjustable (Needle) Valve:	Yes
Serial Number:	217926		
Diaphragm Effective Area	(Extended) and Tolerance:	100.00 in. ² Tol: 3	2.00%
Disabasas Effective Assa	(Detected) and Telegraph	420.00 :- 2 T-I	4.00.0/

	1			
PACKING				
Manufacturer:	Packing Man	Torque applied to Follower Bolts:	25.25	ft-lbs.
Packing Material:	Packing Material	Is the Packing Live Loaded?:	Yes	
Alt Packing Material:	Alternate Material			

ACETest 2012:212
Process MRNE NPC 34.E ric

Page 1 of 4 8/1/2012 9:53:42 AM

- Pre-Test Report
 - Only Accessories chosen are shown

	NUCLEAR MANAGEMENT	Quality Related		
	Browns Ferry Unit 1	Informational Use	Sheet 2	of 3

Work Order: ???????

AOV Data Record Form

AOV ID: BFN-1-LCV-006-0072A

ACCESSORIES

POSITIONER

Equipment ID:	Positioner	Maximum Rated Pressure:	0.0 psig
Manufacturer:	Fisher Controls	Input Range:	3 - 15
Model:	N/A	Input Range Units:	psi
Shop Order Number:	N/A	Input Pressure to Positioner:	0.0 psig
Serial Number:	N/A	Positioner Action:	Direct Acting

AIR REGULATOR

Equipment ID:	Air Regulator	Air Pressure Range (Min/Max):	63.00	1	65.00	psig.
Manufacturer:	Fisher Controls	Setting:	65.00			psig.
Model:	N/A	Maximum Rated Pressure:	0.0			psig.
Shop Order Number:	N/A	Input Pressure:	0.0			psig.
Serial Number:	N/A	AR Supplies:	Positioner			

LIMIT SWITCH

Equipment ID:	Limit Switch 1	Limit Switch 1		Number:	N/A
Manufacturer:	N/A		Serial Number	er:	N/A
Model:	N/A				
Limit Sw #1		Degrees Rotation		Remark (NA if Not Applicable)	
Terminals 1 & 2		Target	Min	Max	
Contacts Close	Decrease Pressure	10.0	8.0	14.0	N/A
Reset		0.0	0.0	0.0	

Equipment ID:	Limit Switch 2	2	Shop Order N	lumber:	N/A
Manufacturer:	N/A	Serial Number: N		N/A	
Model:	N/A				
Limit Sw #2			N/A		Remark (NA if Not Applicable)
Terminals 5 & 6		Target	Min	Max	
Contacts Open	Decrease Pressure	10.0	8.0	14.0	N/A
Reset		0.0	0.0	0.0	

Status NOT APPROVED ACETEST 2012.313 HUN-VPAPP-XADMZ.esolla Page 2 of 3 11/13/2012 5:05:25 PM

- Pre-Test Report
 - Force Settings (Optional)
 - Benchset Settings
 - Testing Requirements

			_
Exelon Nuclear	Quality Related]
Limerick Unit 1	Informational Use	Sheet 3 of 4	

AOV Data Record Form

AOV ID: FCV-006-112A Work Order: NEW W/O

FORCE SETTINGS (lbs) - Measurement Device: EDA

OPEN SETTINGS		Remark (NA if Not Applicable)
Open Adj Min Unseating Force	1,190	Open Min Comment
Open Adj Max Unseating Force	5,799	Open Max Comment
CLOSE SETTINGS		Remark (NA if Not Applicable)
Close Adj Min Seating Force	1,086	Close Min Comment
Close Total Adj Max Seating Force	6,766	Close Max Comment

BENCH SET SETTINGS (psig)

	Betw	reen	Remark (NA if Not Applicable)	
Lower Benchset	1.25	4.01	LRS Comment	
Lower Benchset 1.25 4.01 LBS Comment Lower Benchset Target 2.75 LBS Comment Upper Benchset 14.0 16.0 UBS Comment	LB3 Comment			
Upper Benchset	14.0	16.0	LIBS Comment	
Upper Benchset Target	15,00		OBS Comment	

TEST REQUIREMENTS

Reason for Diagnostic Test	PVT / PM	Packing Adjustment Required:	No
As Found Testing Required:	Yes	Control Room Stroke Time Reqd:	No
Baseline Test	No	Strain Gauge for Thrust Data:	No
As Found LLRT Required:	Yes	Use Installed IP:	Test
Actuator Maintenance Required:	No	High Pressure IP Used:	Yes
Accessory Maint / Calibration:	No	Test Ramp Time:	0

Special Test Instructions:


Special Test Instructions - Tab 19

 Status
 ACETest 2012.212


 Edit in Process
 MRNENPC34.Eric

Page 3 of 4 8/1/2012 9:53:42 AM


- Pre-Test Report
 - Setup Window
 - Optional




- Pre Test Report
 - Detailed Seat load Calc
 - Optional




- Post Test Evaluation
 - Work Done




- Post Test Evaluation
 - Summary
 - Import Data
 - Setpoints calculated
 - Pass/Fail calculated with setpoints
 - Adjusted
 - N/A
 - Yes
 - No




- Post Test Evaluation
 - Evaluation
 - Only QuestionsApplicable to ValveType Shown
 - Questions will be customizable



- Post Test Evaluation
 - Test Log



- Post Test Report
 - Work Performed
 - Test Log
 - Comments



AOV Data Record Form

AOV ID: FCV-006-112A Work Order: NEW W/O

Valve Type: Globe - Pilot - Flow Over Actuator Type: Diaphragm - Direct Acting

Fail Position: Open
Primary AOV Function: Control Valve

WORK PERFORMED

Actuator Maintenance / Overhaul: Yes Packing Replaced: Yes
Positioner Calibrated: Yes Packing Gland Retorqued: Yes
I/P Calibrated: Yes Packing Gland Torque: 75 in-lb:
Accessories Replaced - Accessories Replaced Listed in Comments Below): Yes

AOV VALVE DATA ACQUISITION OPEN / CLOSE STROKE TESTING

AF / AL	TEST TYPE / DESCRIPTION	TE ST DATE	TE ST TIME
As-Found	Baseline	1/1/11	11:11
As-Left	Baseline	2/2/22	22:22
As-Left	Step Open / Step Close	3/3/33	33:33

TESTING COMMENTS

Work Done Comments

Line 1 Line 2

 Status
 ACETest 2012.214
 Page 1 of 4

 NOT APPROVED
 MRNENPC34.Eric
 8/1/2012.1:26:17 PM

- Post Test Report
 - Summary

NUCLEAR	 Quality Related		
MANAGEMENT Test Station Unit 1	 Informational Use	Sheet 2	of 4

AOV Data Record Form

AOVID: RS-007-GL-B-O

Work Order: 2013-0123

0422

TE ST DATA REVIEW

Parameter	As-Found	Setpoint Range		A 1 6	Pass/Fail	Adjusted
Parameter	As-Found	Min Max		- As-Left	(As-Left)	
Total Travel (inch)	0.000	2.690	2.690	0.000	Fail	
Linearity Error (%Decimal)	0.000	0.000	0.000	0.000		
Average Friction (lbf)	0.0	0.0	0.0	0.0		
Lower Benchset (psig)	0.00	0.26	9.92	0.00	Fail	
Upper Benchset (psig)	0.00	18.50	24.30	0.00	Fail	
Spring Rate (lbf/in)	0	540	660	0	Fail	
Seatload (lbf)	0	0	0	0		
Unseating Force (lbf)	0	N/A	N/A	0		
Signal Pressue Lift Off (psig)	0.00	0.00	0.00	0.00		
Signal Pressue Seat (psig)	0.00	0.00	0.00	0.00		
Signal Pressure Full Open (psig)	0.00	0.00	0.00	0.00		
Signal Pressue Start to Close (psig)	0.00	0.00	0.00	0.00		
Linearity Error Positioner (%Decimal)	0.000	0.000	0.000	0.000		
Close Stroke Time (sec)	0.0	N/A	N/A	0.0		
Open Stroke Time (sec)	0.0	N/A	N/A	0.0		
Regulator Pressure (psig)	0.0	5.0	75.0	0.0	Fail	
Limit Switch (Control Signal (psig))	0.0	0.0	0.0	0.0		
Close Margin (%)		0.0		0.0	Pass	
Open Margin (%)		0.0		0.0	Pass	


DISPOSITION FOR OUT OF TOLERANCE CONDITIONS

N/A

 Status
 ACETest 2013.212
 Page 2 of 4

 Edit in Process
 MRNE NPC34.Eric
 8/9/2013 1:26:09 PM

- Post Test Report
 - Evaluation



Status NOT APPROVED ACETest 2012.214 MRNE NPC 34.E ric Page 3 of 4 8/1/2012 1:26:17 PM

- Post Test Report
 - Evaluation (cont)
 - Comments
 - Signoffs

	Exelon Nuclear	Quality Related				
	Limerick Unit 1	Informational Use	She	Sheet 4 of 4		
			A	OV Data Re	ecord For	
AOVID:	FCV-006-112A	Work Order: NEV	W W/O			
Overall Performance	of Actuator					
Is the Pressure output	smooth?		Х			
Does the Actuator Pre	ssure saturate or completely exhaust at th	ne end point?		Х		
Is there sufficient Seat	tload generated by the Actuator at seat co	ntact?			X	
Do abrupt changes in	the Friction correspond to changes in Actu	uator Press?		Х		
Are there any indication	ons of Actuator air leaks?		X			
Do the Actuator Press	ure traces look normal for this type Actuat	tor?		Х		
Are the bench settings	s correct?				X	
Overall Performance	of UD					
Is the Pressure output				Х		
<u> </u>	min pressure cutoff function & if so set pr	onerly?	X	-		
	e over the proper output pressure range?	opony.	^	х		
	ient to cover the expected output pressure	e range?			X	
Overall Performance Is the Travel smooth a Does the valve operate		ję?	X	Х		
	to cause the Posit to cover the expected T			Х		
	sure properly bleed off and saturate at the			^	X	
Eval Comments Line 1 Line 2	JUSTIFICATION	FOR ANY NO AN SWERS				
Prepared By:	Eric Solla	Date:	7/30/2012 1	2:47:18 PI	И	
Reviewed By:	NOT APPROVED	Date:				

ACETest Software

Thank you

USER FEEDBACK?